


WER: Window Energy Performance Certificate

WER Window Energy Rating - In accordance with Approved Document L



Company	Swadlincote Windows Company Ltd.
Date	13 Nov 2025
BFRC System	SC010
BFRC Manufacturer	M1107
BFRC Simplified Energy Licence	SEL 6168

WER:	Window Energy Rating: $196.74((1-f) \times g_{\text{glass}}) - 68.5 \times (U + (0.0165 \times A_L))$	-9.6 kWh/m²/Year
Thermal Transmittance:	WER U Value of Window calculated using the methods and conventions set out in BR443 Whole Window U Value with frame, glazing and glass spacer bar combined. Standard Window configuration set out in BR443/GGF 2.3 U Window: 0.523+0.902+0.139	1.564 W/m²K
Frame:	Supplier: Smart Architectural Aluminium System: Alitherm 400 Outer Frame: ETC4115F (1.687) Vent Frame: ETC4129F (2.314) Transom Mullion: ETC4135F (2.124) Heat Transfer: Uf 2.103 W/m²K x (24.9% Frame)	0.523 W/m²K
Glazing:	Supplier: Saint Gobain Specification: 6.8/18/4 Clear Laminate Ext + Planitherm Total+ Tuff + Argon Warm E Centre Pane, g Value: 1.20 W/m²K, 0.66 Heat Transfer: CP 1.20 W/m²K x (75.1% Glass)	0.902 W/m²K
Spacer:	Supplier: Thermoseal Spacer Bar: Thermobar Heat Transfer: Psi 0.034 W/mK x (4.087m/m²)	0.139 W/m²K
U Value:	Window U Value: Calculation to Document L 2021 1.23m(±25%)x1.48m(-25%)	1.5 W/m²K